CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION OFFICE OF THE STATE FIRE MARSHAL

FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7272-1483:125 Page 1 of 1

CATEGORY: Photoelectric Smoke Detector

LISTEE: Mirtone, 90 Fieldstone Ct., Cheshire, CT 06410

Contact: Brad Miller (888) 649-9827

DESIGN: Models GSA-PS and GSA-PHS photoelectric smoke detectors. Model GSA-PHS employs

> an integral 135NF fixed temperature heat sensor. This heat sensor is a supplementary device to the smoke detector and is not approved as a required heat detector. Refer to listee's printed data sheet for additional detailed product description, installation and

operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances

and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as photoelectric smoke detectors for use with listee's listed fire alarm control units

> and Model GSA Series bases (CSFM Listing No. 7300-1483:122). Model GSA-PS may be suitable for installation directly in the duct with the velocity range from 0-5000

feet/min.

NOTE: Model SIGA-PHS is **not** intended for use in lieu of a required heat detector.

XLF: 7272-1388:186

10-03-97



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

JUNE 15, 2002 Date Issued: Listing Expires June 30, 2003

DIANE K. AREND, Senior Deputy Authorized By:

Program Manager